PureMix X7


High Flow Inline Undersink Filter System



Parts Included



- X7-R filter cartridge
- Valve-in filter head
- · Mounting bracket and screws
- Non-return valve
- · Flexible braided hose
- Stem adaptor
- · Extension kit
- User guide



Width	Height	Depth
81	390	105

Note: All dimensions are in mm.

Specifications

Ordering Co	le Temp °C	Pressure** (kPa)		Micron- Rating*	Connection	Cartridge Size	Capacity*** (L)
PUREMIX-X	2-38	200-520	0-8	1	1/2" BSP (15mm)	12"	37,500

Notes:

The PureMix X7 system is designed specifically for applications with higher sediment and harsher water qualit such as rural supplies, areas with older pipe infrastructure and rainwater.

APPROXIMATE SPACE REQUIRED					
Vertical Mount: 450 mm (h) x 215 mm (w)	Horizontal Mount: 215 mm (h) x 450 mm (w)				

PUREMIX-X7 FILTRATION TECHNOLOGY					
STAGE 1	Removes particles down to 5 micron. Clarifies the water. Reduces sediment, rust, sand, silt and algae.				
STAGE 2	Chlorine and chloramine reduction. Eliminates bad taste and odours. Chemical pesticides & sulphur reduction.				
STAGE 3	Anti-scaling protection. Protection against hardness (i.e calcium & magnesium). Corrosion control.				
STAGE 4	Final filtration down to 1 micron* Fine sediment particle removal.				

Warranty:

Use only genuine Puretec replacement cartridge. 1 year warranty^ is 1 year parts and labour. Excludes cartridges.



Warning Please viol www.puretec.com.aufentuctions to observe essential manufactures' instructions before use Note: No claims can be made based on the operations and manges in this cloumment. The design technology, crious, features and prices are subject to drange. This cloumment had all its contents are copyright protected. All rights are reserved, particularly alteration, translation and reproduction using electron systems. This spec sched has been dissigned to be formable product selection asset however due to the complex nature of water chemistry, we strongly encourage confirming any product selection with one of our team. We may need to perform a water analysis test to confirm contaminants in water Caution: Do not use with microbiologically urisaled water or water of urishrow quality without a decayated selection before or after the system Warnagh. "Marrantes in this document cover parts for the period stated and include cover for parts and labour for the first year where applicable, subject to approval. Excludes consumables our Water Elitation Specialists can provide you with abuse to suit you reneeds." "Member liter prosesses" 500Pag. an approved pressure limiting device must be installed to comply with Australian A. New Zelain Plumbing Standards, Ref. AS 55001.2012, Clause 3.541, Maximum from dependent our cartifiques, seesal, pressure, impurpatives et. "Moreon raining" in sommal." "Capacity is based on intell chindren degragm 1.05". The term

